

10A NCAC 13G .0311 CORRIDOR

- (a) Corridors shall be a minimum clear width of three feet in family care homes.
- (b) Corridors shall be lighted with night lights providing 1 foot-candle power at the floor.
- (c) Corridors shall be free of all equipment and other obstructions.

*History Note: Authority G.S. 131D-2.16; 143B-165;
Eff. January 1, 1977;
Readopted Eff. October 31, 1977;
Amended Eff. July 1, 2005; April 1, 1984;
Recodified from 10A NCAC 13G .0310 Eff. July 1, 2005;
Pursuant to G.S. 150B-21.3A, rule is necessary without substantive public interest Eff. February
16, 2019.*