

10A NCAC 13S .0209 ELEVATOR

- (a) In multi-story buildings, the clinic shall provide at least one elevator for patient use.
- (b) At least one dimension of the elevator cab shall be six and one-half feet to accommodate stretcher patients.
- (c) The elevator door shall have an opening of no less than three feet in width, which is minimum for stretcher use.

*History Note: Authority G.S. 131E-153.5; 143B-165;
Codifier determined that findings of need did not meet criteria for emergency rule on October 30, 2023;
Emergency Rule Eff. November 14, 2023;
Temporary Adoption Eff. February 8, 2024.*