

**10A NCAC 13S .0211 DOORS**

Minimum width of doors to all rooms needing access for stretchers shall be three feet. No door shall swing into corridors in a manner that might obstruct traffic flow or reduce the required corridor width except doors to spaces not subject to occupancy.

*History Note: Authority G.S. 131E-153.5; 143B-165;  
Codifier determined that findings of need did not meet criteria for emergency rule on October 30, 2023;  
Emergency Rule Eff. November 14, 2023;  
Temporary Adoption Eff. February 8, 2024.*