

**10A NCAC 14J .1505 SINGLE ROOM REQUIREMENTS**

- (a) Single room areas shall be a minimum of five feet by seven feet by eight feet.
- (b) The room shall have a combination lavatory, commode and drinking fountain (see Rule .1534 of this Section).
- (c) Isolation rooms shall have hot and cold water.
- (d) Except for local lockups, a shower with hot water shall be provided for each area of isolation rooms.
- (e) An approved mirror shall be installed (see Rule .1521 of this Section).
- (f) No more than one approved stationary steel bunk shall be installed in the room (see Rule .1522 of this Section).
- (g) Natural light shall be admitted to the room in compliance with the North Carolina State Building Code.

*History Note:* Authority G.S. 153A-220; 153A-221;  
Eff. June 1, 1990;  
Pursuant to G.S. 150B-21.3A, rule is necessary without substantive public interest Eff. January 5,  
2016.