

10A NCAC 42D .0261 RADIOCHEMISTRY ACTION RESPONSE

All laboratory results exceeding maximum contaminant levels shall be reported to the Public Water Supply Section of the Division of Environmental Health within 48 hours. All other laboratory results shall be reported in accordance with the Public Water Supply rules in 15A NCAC 18C.

History Note: Authority G.S. 130A-315;
Eff. December 1, 1991;
Pursuant to G.S. 150B-21.3A, rule is necessary without substantive public interest Eff. December 23, 2017.