

10A NCAC 70K .0310 CORRIDORS

- (a) Corridors shall be a minimum clear width of three feet.
- (b) Corridors shall be lighted with night lights providing one foot candle of light at the floor.
- (c) Corridors shall be free of all equipment and other obstructions.

*History Note: Authority G.S. 131D-1; 143B-153;
Eff. October 1, 2008;
Pursuant to G.S. 150B-21.3A, rule is necessary without substantive public interest Eff. April 5,
2016.*