

**11 NCAC 05A .0904      FACILITIES**

- (a) A fire station shall be provided with heating for all-weather protection of apparatus.
- (b) If a fire department has multiple fire stations, each fire station shall not be more than 10 road miles from another fire station within the fire district.

*History Note:*      *Authority G.S. 58-2-40; 58-36-10; 58-40-25;*  
*Eff. January 1, 2018.*