

## SECTION .0200 - PROGRAM SCOPE AND INTERIM PROHIBITION

### 15A NCAC 02N .0201 APPLICABILITY

The regulations governing "Applicability" set forth in 40 CFR 280.10 are hereby incorporated by reference, excluding any subsequent amendments and editions, except that:

- (1) underground storage tanks (UST) containing de minimis concentrations of regulated substances are also subject to the requirements for permanent closure in Rules .0802 and .0803 of this Subchapter; and
- (2) UST systems that store fuel solely for use by emergency power generators installed on or after November 1, 2007 shall also meet the requirements of Section .0900 of this Subchapter.

*History Note: Authority G.S. 143-215.3(a)(15); 143B-282(a)(2)(h);  
Eff. January 1, 1991;  
Amended Eff. June 1, 2017; November 1, 2007;  
Readopted Eff. January 1, 2021.*