

**15A NCAC 18A .0603 HOT WATER SYSTEM**

An automatically regulated hot water system shall be provided that has capacity to furnish water at a temperature of at least 130°F during all hours of shucking and packing plant operation.

*History Note: Authority G.S. 113-134; 113-182; 113-221.2; 143B-289.52;  
Eff. February 1, 1987;  
Readopted Eff. April 1, 2024.*