

**15A NCAC 18A .1016 LODGING FACILITIES**

Permanent sleeping quarters shall provide cross ventilation, at least 30 inches between beds, a minimum of six feet between heads of sleepers and at least one bed for every camper. Only single beds or double level bunk beds shall be allowed. Lodging facilities, whether provided by the camp or by individual campers, shall be kept clean and in good repair. Clean linen and soiled linen shall be stored and handled separately and in a sanitary manner.

*History Note: Authority G.S. 130A-248;  
Eff. February 1, 1976;  
Readopted Eff. December 5, 1977;  
Amended Eff. October 1, 1992; September 1, 1990;  
Pursuant to G.S. 150B-21.3A, rule is necessary without substantive public interest Eff. July 20, 2019.*