

15A NCAC 18A .3510 DRINKING WATER FACILITIES

Drinking water facilities shall be provided. Drinking fountains, if provided, shall be of a sanitary angle-jet design, shall be kept clean and shall be regulated such that water flow is at least two inches above the mouth piece. This Rule shall not be interpreted as prohibiting the pitcher service of water or the service of bottled water.

*History Note: Authority G.S. 130A-248;
Eff. May 1, 2004;
Pursuant to G.S. 150B-21.3A, rule is necessary without substantive public interest Eff. July 20, 2019.*