

15A NCAC 18A .3609 WATER SUPPLY

- (a) In Resident Camps, water supplies shall be in accordance with 15A NCAC 18A .1700, Rules Governing the Protection of Water Supplies.
- (b) Water samples for bacteriological analysis from non-community supplies shall be collected by the Department and submitted to the North Carolina State Laboratory of Public Health or another lab certified by the North Carolina State Laboratory of Public Health for analysis, at least annually for bacteriological analysis.
- (c) Prior to issuance of a permit, the responsible person shall list non-community water supplies with the Public Water Supply Section, Division of Environmental Health.
- (d) Cross-connections with unapproved water supplies, sewage lines or other potential sources of contamination are prohibited.
- (e) Hot water heating facilities shall be provided. Hot and cold running water under pressure shall be provided to food preparation, utensil and handwashing areas, and any other areas in which water is required for cleaning. Running water under pressure shall be provided in sufficient quantity to carry out all food preparation, utensil washing, handwashing, cleaning and other water-using operations.

*History Note: Authority G.S. 130A-235; 130A-248;
Eff. October 1, 2007;
Pursuant to G.S. 150B-21.3A, rule is necessary without substantive public interest Eff. July 20, 2019.*