

15A NCAC 18C .0408 LEAD FREE CONSTRUCTION

(a) All pipe, pipe fitting, solder or flux used in the installation or repair of a public water system shall be lead free.

(b) "Lead free" means:

- (1) not containing more than 0.2 percent lead when used with respect to solder and flux; and
- (2) not more than a weighted average of 0.25 percent lead when used with respect to the wetted surfaces of pipes, pipe fittings, plumbing fittings, and fixtures.

*History Note: Authority G.S. 130A-315; P.L. 93-523; 40 C.F.R. 141;
Eff. June 1, 1988;
Amended Eff. August 1, 2002;
Readopted Eff. July 1, 2019.*