

**15A NCAC 18C .0604 PUMPS: POWER FACILITIES**

At least two pumping units with necessary check valves, gate valves, piping and appurtenances shall be provided for both raw water and finished water. Auxiliary facilities shall be provided to supply power or to provide other means to satisfy the design minimum water needs of the system.

*History Note: Authority G.S. 130A-315; 130A-317; P.L. 93-523;  
Eff. January 1, 1977;  
Readopted Eff. December 5, 1977;  
Pursuant to G.S. 150B-21.3A, rule is necessary without substantive public interest Eff. November 23, 2015.*