

SECTION .0800 - HYDROPNEUMATIC STORAGE TANKS RULES

.0801 - .0805 of Title 15A Subchapter 18C of the North Carolina Administrative Code (T15A.18C .0801 - .0805); has been transferred and recodified from Rules .2001 - .2005 Title 10 Subchapter 10D of the North Carolina Administrative Code (T10.10D .2001 - .2005), effective April 4, 1990.

15A NCAC 18C .0801 CAPACITIES: DETERMINING MINIMUM EFFECTIVE VOLUME

The minimum effective volume of pressure tanks, in gallons, shall equal the peak demand, in gallons per minute, minus the pumping capacity (gpm), multiplied by 20.

History Note: Authority G.S. 130A-315; 130A-317; P.L. 93-523;
Eff. January 1, 1977;
Readopted Eff. December 5, 1977;
Pursuant to G.S. 150B-21.3A, rule is necessary without substantive public interest Eff. November 23, 2015.