

15A NCAC 18C .0804 CAPACITIES: GROUND STORAGE PLUS HYDROPNEUMATIC TANKS

When ground level storage tanks and high-service pumps are to be used, hydropneumatic tanks shall be sized in relation to peak demand and the high-service pump capacity.

History Note: Authority G.S. 130A-315; 130A-317; P.L. 93-523;
Eff. January 1, 1977;
Readopted Eff. December 5, 1977;
Amended Eff. July 1, 1994;
Pursuant to G.S. 150B-21.3A, rule is necessary without substantive public interest Eff. November 23, 2015.