

15A NCAC 18C .1515 ORGANIC CHEMICALS OTHER THAN TTHM, SAMPLING AND ANALYSIS

(a) The requirements of this Rule shall apply to community and non-transient non-community water systems. The provisions of 40 C.F.R. 141.24 are incorporated by reference, including subsequent amendments and editions. Copies may be obtained as set forth in Rule .0102(b) of this Subchapter.

(b) If the result of an analysis made pursuant to Paragraph (a) of this Rule indicates that the level of any contaminant regulated under this Subchapter exceeds the maximum contaminant level, the supplier of water shall report to the Department within 48 hours of receipt of the analytical result.

*History Note: Authority G.S. 130A-315; P.L. 93-523; 40 C.F.R. 141;
Eff. September 1, 1979;
Amended Eff. November 1, 1989; December 1, 1988; June 1, 1988; October 1, 1982;
Transferred and Recodified from 10 NCAC 10D .1624 Eff. April 4, 1990;
Amended Eff. April 1, 2014; August 1, 2002; April 1, 1992; December 1, 1991; September 1,
1990;
Readopted Eff. July 1, 2019.*