

#### **15A NCAC 18E .1104 SIPHON DOSING**

Siphons and siphon tanks may be used when a minimum of two feet of elevation drop is maintained between the siphon outlet invert and the inlet invert in the dispersal field distribution system. Siphons and siphon tanks shall meet the following criteria:

- (1) Slope and size of the siphon discharge line shall be sufficient to handle the peak siphon discharge by gravity flow without the discharge line flowing full. Vents for the discharge lines shall be located outside of the siphon tank and shall not serve as an overflow for the tank.
- (2) All siphon parts shall be installed in accordance with the manufacturer's specifications. All materials shall be corrosion-resistant, of cast iron, high-density plastic, fiberglass, stainless steel, or equal as approved by the Department when documentation is provided which shows the materials meet the requirements of this Rule.
- (3) Siphon tanks shall have a functioning trip counter and high-water alarm. The high-water alarm shall be audible and visible by system users and weatherproof if installed outdoors in an enclosure rated as NEMA 4X at a minimum. The high-water alarm shall be set to activate within two inches of the siphon trip level.

*History Note: Authority G.S. 130A-335(e), (f), and (f1);  
Eff. January 1, 2024.*